## **Department of Property & Procurement**

Government of the United States Virgin Islands

3274 ESTATE RICHMOND, CHRISTIANSTED, U. S. VIRGIN ISLANDS 00820 8201 SUB BASE, SUITE 4, ST. THOMAS, U. S. VIRGIN ISLANDS 00802 ST. CROIX MAIN OFFICE: 340.773.1561 ST. THOMAS MAIN OFFICE: 340.774.0828 ST. CROIX FAX: 340.773.0986 ST. THOMAS FAX: 340.777.9587



HTTP://DPP.VI.GOV

## **AMENDMENT ONE (1)**

August 22, 2018

TO:		
SUBJECT:	IFB054DPWC18 (C) Repairs to Route 63 along Whim Ball Park), Frederiksted, St. Croix	

**INSERT:** Question & Answer

For line item 305.01 – Full Depth Reclaiming, can a roadway milling machine be used in place of the roadway reclaiming machine?

Based on FP-14 section 305 specifications the only requirement not met by the milling machine is the width of the cutting drum; 8 ft wide vs the milling width of 5-6 ft. The milling machine will meet the same depths and can pulverize the road in place.

**A.** In response to your question as whether a milling machine can be used in lieu of a reclaiming machine that answer would be yes. Either machine will do.

All other terms and conditions remain the same.

A copy of this amendment must be returned with your bid.